

## Performance of Windows and Doors

### Following the principles of BS 1191: 2012 Windows and Doors- Resistance to repeated opening and closing

#### CONFIDENTIAL

Report reference: CW19098

Issue date: 2<sup>nd</sup> September 2019

Project: Single leaf doorset

Prepared for: Yildiz Entegre Romania SA  
1 Yildiz Street ,  
Oarja117545 ,  
Arges Count / Romania

Test Engineer(s): Dennis Humm

**Build Check Ltd**  
Montrose House  
Lancaster Road  
Cressex Business Park  
High Wycombe  
Bucks HP12 3PY

Tel: 01494 452713 Fax: 0870 210 1013  
E-mail: [info@buildcheck.co.uk](mailto:info@buildcheck.co.uk)

*This document is confidential and remains the property of Build Check Ltd*

*The results contained in this report relate only to the specimens tested and do not necessarily relate to samples from the production line of the above named company. This report does not constitute in any way a warranty or representation to the performance or quality of the said product. The above named company has supplied all technical specifications. Build Check Ltd and its representatives accept no liability for misuse of this report.*

*The legal validity of this report can only be claimed on presentation of the complete report.*

## 1 Introduction

This document describes the testing on the Single leaf doorset, conducted in accordance with BS EN 1191: 2012 and BS EN 12046-1.

The testing was commissioned by Ahmet Kocat on behalf of Yildoz Entegre A.S. All specimens were selected and supplied by the client.

The testing was carried out by Build Check Ltd test laboratory at Unit 3 Lincoln Business Centre, Lincoln Road, High Wycombe, HP12 3RD. The testing was conducted from 17 March. The testing was not witnessed.

This report is only valid for the conditions under which the test was conducted. All measurement devices, instruments and other relevant equipment are calibrated and traceable to National Standards.

## 2 Summary of Results

The following summarises the results of testing carried out, in accordance with the relevant test methods and classification standards (see section 5 for more details).

<b>Operating Forces</b>	<b>Test Method Ref</b>	<b>Classification Ref</b>	<b>Classification Achieved</b>
Operating Forces	BS EN 12046-1	BS EN 12217	2

  

<b>Mechanical Strength</b>	<b>Test Method Ref</b>	<b>Classification Ref</b>	<b>Classification Achieved</b>
Resistance to repeated opening and closing	BS EN 1191	BS EN 12400:2002	5

The doorset range covered by this report is only applicable to the size and configuration tested.

*The legal validity of this report can only be claimed on presentation of the complete report.*

### 3 Authorisation

	Issued by:	Checked by:
<b>Signature:</b>		
<b>Name:</b>	Dennis Humm	Richard Bate
<b>Title:</b>	Test Engineer	Technical Director

### 4 Test Details

Configuration: Single leaf doorset

Nominal Overall Dimensions:  
 Outer frame (w x h): 865mm x 2025mm  
 Door leaf (w x h): 800mm x 1980mm

The specimen(s) were received on: 17/03/2019

The test sample(s) were selected and provided direct from the client.

The specimen was conditioned in the laboratory for at least four hours, at a temperature between 15 to 30°C and a relative humidity between 25 to 75%.

The laboratory ambient air temperature at the start of test was 16°C

The doorset specimens were supplied in good condition, mounted into a nominally 50mm x 100mm sub-frame in accordance with the manufacturer's installation requirements. They were secured into the test rig by the responsible engineer.

*The legal validity of this report can only be claimed on presentation of the complete report.*

#### 4.1 Description of Specimen

Description of specimen was supplied by the client and not verified by Build Check – for further information see drawings.

Frame Profiles	Ref. No.	Material Type, Manufacturer's Name, Density (timber only) & Surface Treatment	Dimensions (Height & Width)
Outer Frame	-	Monoblok Mdf / Yildiz entegre SA	865mm x 2025mm
Door leaf	-	Monoblok Mdf / Yildiz entegre SA	800mm x 1980mm
Joint Type	Screw Jointing		

Weather Seals	Ref. No.	Material Type/ Manufacturer's Name	Continuous or Joined @ Corners
Frame Rebate	-	Monoblok Mdf / Yildiz entegre SA	Joined

Hardware	Ref. No.	Manufacturer's and Product Name	Fixings
Lock	221	Kale kilit	2No. Kale 3.8x18mm Chipboard screws
Lock Keeps	-	Kale Kilit	2No. Kale 3.8x18mm Chipboard screws
Handles	-	Hafele	4No. Sofuoğlu 3.5x18mm chipboard screws.
Hinges/ Friction Stays	-	3No. Variodor, Lift off Hinges	4No. Sofuoğlu 5.7x40mm Chipboard Screws into frame. 4No. Sofuoğlu 5.7x40mm into leaf each.

*The legal validity of this report can only be claimed on presentation of the complete report.*

## 5 Performance Requirements and Results

### 5.1 Resistance to repeated opening and closing

#### Primary sash Initial measurements

Description	Test 1	Test 2	Test 3	Average	Stroke of moving component
Disengage Latch (Measured on handle in N)	31.0	29.6	30.8	30.47	45°
Commence Opening (Measured on handle in N)	9.9	5.9	3.6	6.47	90°
Commence Closing (Measured on handle in N)	13.2	5.9	3.7	7.6	90°

#### Final measurements

Description	Test 1 (N)	Test 2 (N)	Test 3 (N)	Average (N)	Stroke of moving component
Disengage Latch (Measured on handle in N)	20.1	23.2	19.8	21.03	45°
Commence Opening (Measured on handle in N)	7.2	11.1	10.2	9.5	90°
Commence Closing (Measured on handle in N)	14.1	9.8	10.1	11.33	90°

#### Variation in performance

Description	Variation in performance %
Handle down force	31%
Leaf opening force	46.8%
Leaf closing force	49.1%

The number of cycles completed by the opening leaf was 100,000, as required by class 5 of the standard. Lubrication and maintenance was not performed. The stroke of the leaf was 90 degrees with a casement weight of 37kg and a dead load of 0.2kg. The fastening system was operated. No signs of excessive wear were apparent.

*The legal validity of this report can only be claimed on presentation of the complete report.*

**Figure 1 – Photograph of Specimen**



*The legal validity of this report can only be claimed on presentation of the complete report.*